

CITY OF FORT WORTH
TRANSPORTATION AND PUBLIC WORKS DEPARTMENT

ADDENDUM NO. 1
WATER & SEWER IMPROVEMENTS
TO SERVE
TOLIVER RV DEALERSHIP AT ALLIANCE

IPRC21-0033
CITY PROJECT NO. 103285

ADDENDUM RELEASE DATE: August 30, 2021

INFORMATION TO BIDDERS:



The Plans for the above referenced project are hereby revised and amended as follows:

1. The following item is an RFI that came up during bidding:
 - a. Q: We noticed that a segment of the WL from sta. 18+00 to sta. 27+00 is omitted from the issue set.
 - b. A: The plan set has been updated to show the omitted section. Sheet 7 now shows section from sta. 18+00 to sta. 27+00 and sheet 8 shows section from sta. 27+00 to sta. 33+50.
2. The following item is an RFI that came up during bidding:
 - a. Q: There is no restoration item for the green areas, is hydromulch/seed/sod intended to be included?
 - b. A: Yes, will be added to bid items
3. The following item is an RFI that came up during bidding:
 - a. Q: The scope of the cased pipe conflicts from plans to contract bid items. Is it the Owner's intent for cased pipe at Sta. 35+00 to be installed by open cut or by bore?
 - b. A: By bore, as indicated in plans. Will update bid items.
4. The following item is an RFI that came up during bidding:
 - a. Q: Noticed small section of sidewalk will need replacing at Eagle Parkway.
 - b. A: Will add to bid items

Please acknowledge receipt of the Addendum in the following locations:

- (1) In the space provided below
- (2) Indicate in upper case letters on the outside of the sealed bid envelope:
"RECEIVED & ACKNOWLEDGED ADDENDUM NO. 1"

Failure to acknowledge the receipt of Addendum No. 1 could cause the subject bidder to be considered "NON-RESPONSIVE", resulting in disqualification. A signed copy of this addendum shall be placed into the proposal at the time of bid submittal.

**TOLIVER RV DEALERSHIP AT ALLIANCE
ADDENDUM #1**

RECEIPT ACKNOWLEDGED:

By: _____

Title: _____