



Inspection Guidance Document

This document is not intended to provide a comprehensive list of all requirements for all projects. The information listed below is intended to provide general guidance on what inspectors will be looking for during the inspection. For complete requirements see the City of Fort Worth Zoning Ordinance and adopted building and trade codes.

255 – Electrical Wall

- Approved plans and permit card onsite.
- All boxes, conduits, and cables must be located and secured per NEC.
- Connectors, couplings and other fitting must be tight.
- Conduits and cables shall be mechanically secured at boxes and panelboards.
- Verify all metal boxes are grounded.
- Nail plates for cables within 1 ¼ in. of face of a framing member.

DEVELOPMENT SERVICES DEPARTMENT

THE CITY OF FORT WORTH * 100 FORT WORTH TRL * FORT WORTH, TEXAS 76102
WWW.FORTWORTHTEXAS.GOV