



Inspection Guidance Document

This document is not intended to provide a comprehensive list of all requirements for all projects. The information listed below is intended to provide general guidance on what inspectors will be looking for during the inspection. For complete requirements see the City of Fort Worth Zoning Ordinance and adopted building and trade codes.

325 – Mechanical Ceiling

- Approved plans and permit card onsite.
- Verify all duct in walls are installed and sealed.
- Verify drain piping is installed and supported with proper slope. Verify joints and connections of drain lines are installed with correct materials.
- Verify refrigerant lines are installed & supported with insulation. (R3)
- Verify refrigerant lines insulation properly glued. (per Manufacturer's instructions)
- Verify nail plates are installed for protection of refrigerant piping and ductwork.

DEVELOPMENT SERVICES DEPARTMENT

THE CITY OF FORT WORTH * 100 FORT WORTH TRL * FORT WORTH, TEXAS 76102
WWW.FORTWORTHTEXAS.GOV