



Inspection Guidance Document

This document is not intended to provide a comprehensive list of all requirements for all projects. The information listed below is intended to provide general guidance on what inspectors will be looking for during the inspection. For complete requirements see the City of Fort Worth Zoning Ordinance and adopted building and trade codes.

420 – Plumbing Sewer/Yard

- Approved plans and permit card onsite.
- Verify proper use of drain and vent piping and fittings.
- Verify drainage piping sized correctly.
- Verify drainage piping slope as required based on pipe size.
- Verify piping properly excavated & bedded.
- Verify piping protection from physical damage.
- Verify drain lines are filled and ready for a water test.
- Verify that a two-way cleanout is installed as required a maximum of every 100' apart.

DEVELOPMENT SERVICES DEPARTMENT

THE CITY OF FORT WORTH * 100 FORT WORTH TRL * FORT WORTH, TEXAS 76102
WWW.FORTWORTHTEXAS.GOV